

# THE CONNECTICUT STATE UNIVERSITY

P.O. Box 2008 • New Britain, Connecticut 06050 • (203) 827-7700

### RESOLUTION

#### concerning

## AUTHORIZATION TO PERFORM REPAIRS TO FACILITIES SUPPORTED BY THE AUXILIARY SERVICES FUND at SOUTHERN CONNECTICUT STATE UNIVERSITY

## March 1, 1985

- WHEREAS, The burner units for the boilers in Schwartz Hall of Southern Connecticut State University have deteriorated and have malfunctioned causing a loss of heat and hot water, therefore be it
- RESOLVED, That Southern Connecticut State University is authorized to install two new oil/gas burner units in the existing boilers in Schwartz Hall at an estimated cost of \$30,000, the cost to be met from the Connecticut State University Administration Auxiliary Services Account.

A Certified True Copy:

James A. Frost President

Central Connecticut State University • New Britain Eastern Connecticut State University • Willimantic Southern Connecticut State University • New Haven Western Connecticut State University • Danbury